



KERALA WATER AUTHORITY

Phone :04862220719

QUALITY CONTROL SUB DISTRICT LAB, THODUPUZHA IDUKKI-685585

WATER TEST-BACTERIOLOGY REPORT

email-qcsdltdpa@gmail.com

KWA/QCSDL/TDPA/F/6/4118/26-27		Report Issue Date : 05/08/2026		
Customer Name & Address SANJO CMI PUBLIC SCHOOL KODUVELY		Date of Receipt of Payment		
		31.07.2026		
		Date of Sample recived		31.07.2026
		Sampling Given by		Customer
		Sample Code		TDPA 4118
		Sample Name		Well Water
		Sample Condition		Good
		Source of Sample		Well
		Sample Quantity		200 ml
Test performing dates		From: 03/08/2026 to 05/08/2026		
Sl. No.	Source	Test Method	No of Total Coliforms per 100ml of sample	E.Coli in 100ml of sample
1	Water sample submitted by the customer	IS 15185:2016 (Reaffirmed 2021)	Present	Present

Remarks:-

NB:-The result stated above related only to the sample(s) submitted for testing by the customer. The test certificate shall not be reproduced except in full without the written approval of the Laboratory.



Analysed by
Name & Designation

Analysed by
Arathy. P.S.
Bacteriologist

KWA/QCSDL/TDPA/F/05	Issue : 1	Issue Date : 01.07.2021
Rev. No: 1	Rev.Date : 01.03.2022	Page 3 of 3

End of Report



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, THODUPUZZHA, IDUKKI-685585

Phone : 04862220719

(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)

WATER TEST REPORT

- qcsdltdpa@gmail.com

Report Issue Date : 05/08/2026

Customer Name & Address			Date of Receipt of Payment	31.07.2026		
SANJO CMI PUBLIC SCHOOL KODUVELY			Date of Sample Received	31.07.2026		
			Sampling Given by	Costumer		
			Sample Code	TDPA 4118		
			Sample Name	Well Water		
			Sample Condition	Good		
			Source of Sample	Well		
			Sample Quantity	2 Litre		
			Test performing date	From: 31/07/2026 To: 31/07/2026		
Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Permissible limits in absence of alternate source	Result
1	Turbidity	(NTU)	IS 3025 (Part10)-2023	1.0	5.0	1.20
2	P ^H at 25 °C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	No relaxation	6.9
3	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32)-2025	250	1000	11.7
4	Total Hardness (as CaCO ₃)	(mg/litre)	IS 3025 (Part21)-2009(Reaffirmed 2023)	200	600	23.50

Remark :
NB:-The result stated above related only to the sample(s) submitted for testing by the customer.The test certificate shall not be reproduced except in full without the written approval of the Laboratory



Analysed By

Signature
CHEMIST
Quality Control Subdistrict Lab
Kerala Water Authority
Thodupuzha - 685 585

KWA/QCSDL/TDPA/F/6	Issue : 1	Issue Date : 01.07.2021
Rev. No: 12	Rev.Date : 09.10.2024	Page 1 of 3

End of Report



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB, THODUPUZZHA, IDUKKI-685585
WATER TEST REPORT

Phone : 04862220719

• qcsdltdpa@gmail.com

Report Issue Date : 05/08/2026

Customer Name & Address SANJO CMI PUBLIC SCHOOL KODUVELY			Date of Receipt of Payment	31.07.2026		
			Date of Sample Received	31.07.2026		
			Sampling Given by	Customer		
			Sample Code	TDPA 4118		
			Sample Name	Well Water		
			Sample Condition	Good		
			Source of Sample	Well		
			Sample Quantity	2 Litre		
			Test performing date	From: 31/07/2026 To: 31/07/2026		
Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Permissible limits in absence of alternate source	Result
1	Nitrate (as NO ₃)	(mg/litre)	Phenol Di- Sulphonic Acid Method	45	No relaxation	15.00
2	Iron (as Fe)	(mg/litre)	IS 3025 (Part 53)-2024	1	No relaxation	0.10
3	Electrical conductivity at 25°C	(micromhos/cm)	IS 3025(Part 14)-2013 (Reaffirmed 2019)	-	-	104.90

Remark :

NB:-The result stated above related only to the sample(s) submitted for testing by the customer.The test certificate shall not be reproduced except in full without the written approval of the Laboratory



Analysed By

Shajin

CHEMIST

Quality Control Subdistrict Lab
Kerala Water Authority
Thodupuzha - 685 585

KWA/QCSDL/TDPA/F/6	Issue : 1	Issue Date : 01.07.2021
Rev. No: 12	Rev.Date : 09.10.2024	Page 2 of 3

End of Report